


PROFORMA FOR DETERMINING ENERGY EFFICIENCY USING R1									
Site name		North Wales Deeside Site		Permit reference					
What data has been used in the application? →		Design data							
Details of who to contact if we have any queries regarding this form									
									
Indicative R1 factor (subject to confirmation)	0.76	Quantity in reporting year	Units	U <sub>e</sub>	Properties (Average over reporting year)	Units	Note which parameters that have been estimated	Reference to Supporting information	
1. Gross electricity meter (Electricity produced at turbine)		131472	MWh						Water-Steam cycle
2. Electricity exported - Net input/output meter		115695	MWh				12% Parasitic Load		Assumed
3. Electricity imported - Net input/output meter		75	MWh				0.5MW for 150h/year		Assumed
4. Other fuel inputs									
4.1 Light fuel oil		217620	litres		0.93	ka/l			3 cold start ups @ 25000kg
4.2 Natural gas			Nm <sup>3</sup>		42800	kJ/kg			Fuel consumption for start
4.3 LPG			Nm <sup>3</sup>		34200	kJ/Nm <sup>3</sup>			
4.4 Other fuels similar to light fuel oil			litres			kg/l			
5. Primary combustion air (as supplied to furnace)		577728000	Nm <sup>3</sup>		100	°C			
					1.287	kg/Nm <sup>3</sup>			
					75.75	kJ/kg			Water-Steam cycle
6. Secondary combustion air (as supplied to furnace)		510624000	Nm <sup>3</sup>		100	°C			
					1.287	kg/Nm <sup>3</sup>			
					75.75	kJ/kg			Water-Steam cycle
7. Recycled flue gas (as supplied to furnace)			Nm <sup>3</sup>			°C			
						kg/Nm <sup>3</sup>			
						kJ/kg			
8. Heat exported outside R1 boundary									
8.1 steam exported			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
8.2 hot water exported			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
9. Internal steam use									
9.1 for soot blowing (no backflow)			tonnes			°C			Mechanical rapping and shot cleaning used instead.
						kPa			
						kJ/kg			
9.2 for steam driven devices		2864	tonnes			418.7	°C		Steam for evacuation of ACC. Water-Steam cycle.
						5800	kPa		
						3230	kJ/kg		
						40.5	°C		
						100	kPa		Steam for evacuation of ACC. Water-Steam cycle.
						168	kJ/kg		
9.3 for trace heating			tonnes			°C			Electrical trace heating used.
						kPa			
						kJ/kg			
						°C			
						kPa			Electrical trace heating used.
						kJ/kg			
9.4 for re-heating flue gas			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
9.5 for concentration processes			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
9.6 for building, equipment, tank heating			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
9.7 for deaeration and demineralisation			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
9.8 other internal applications, in line with commission guidance, to be specified			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
9.9 other internal applications, in line with commission guidance, to be specified			tonnes			°C			
						kPa			
						kJ/kg			
						°C			
						kPa			
						kJ/kg			
10. Use of condensing energy from steam in flue gas									
11. Superheated steam at boiler outlet		578856	tonnes			420	°C		
						6000	kPa		
						3230	kJ/kg		Water-Steam cycle
12. Boiler feedwater		583024	tonnes			130	°C		
						8150	kPa		
						562	kJ/kg		Water-Steam cycle
13. Boiler efficiency		87%		=		1.5%			Water-Steam cycle

**Instructions for completing this spreadsheet**

- Ensure that you have completed the first three rows of the application form
- This form should be accompanied by supporting information for the figures quoted. Where this information is in the permit application, reference to the relevant sections of the application can be made.  
A Sankey diagram (or equivalent) reflecting the boundaries of the installation used as well as any references to physical properties is the absolute minimum that should be provided for an application based on design information
- We have colour coded the cells in this spreadsheet to assist you in completing this form, an explanation of the colour codes is provided below. The colour will disappear when data has been entered.  
  - Blue cells require data that is essential for the R1 calculation, where information on uncertainty of the data is available it would be useful (but not mandatory) for this to be included for these parameters.
  - Beige Cells indicate that any data entered will be used in the R1 calculation. They have been used where there is a choice of inputs but not all plants will have data for all the input options.
  - Where you are entering data into beige cells you need to make sure that you enter data into all the beige cells associated with the input as they are all needed for carrying out the calculation.
  - Yellow cells have been used to provide flexibility to include fuels or energy uses not identified elsewhere. Supporting information to explain why the standard fields were not appropriate or adequate will need to be provided where these cells are used
  - Data entered in uncoloured cells are not used when calculating the R1 energy efficiency factor but can be completed to provide a more complete data set.
- If you believe that any of the information that you have submitted in this application form is commercially confidential please identify the confidential information and the grounds on which you believe it to be confidential in your covering letter

LT 5753  
EAD/0812/MS/V2.3